## GAZELLE<sup>®</sup>

## **Insulation Resistance Tester, 2.5kV**

G9300 Series - G9310

The GAZELLE G9310 Insulation Resistance Tester, 2.5kV plays an important role in testing insulation resistance during maintenance and troubleshooting of large transformers, generators, high-voltage motors, electrical wiring work, plant equipment management, and more. It can swiftly identify system problems that could potentially cause safety hazards and production downtime. The instruments are portable and user-friendly with enhanced functionality. The G9310 can also measure PI, DAR and other important specifications. Measured data can then be analysed through PC software.





- Large 9999 display with 30-segment analog bar graph
- PI/DAR measurements & Continuous measurement mode
- Comparison, upper and lower limit functions with 18-group data storage
- Auto power off, backlight, and low battery & over range indications
- Auto current discharge and high-voltage output alarm
- Power adapter, USB interface and PC software
- Time measurement mode, auto measure within 15 minutes

## **Standard Accessories**

- 2 pcs. 1 Plug Test Lead to 1 Alligator Clip
- 1 pc. 2 Plugs Test Lead to 1 Alligator Clip
- Batteries

- USB Cable
- PC Software CD Power Adaptor

Specifications		Range	Best Accuracy
		100V~1000V	
	Test Voltages	500V~2500V	0%~20
-	100V	0.1ΜΩ~500ΜΩ	
	250V	0.5 <b>Μ</b> Ω~2GΩ	
	500V	1 <b>Μ</b> Ω~4 <b>G</b> Ω	
Insulation Resistance		0.5ΜΩ~5GΩ	±(3%+5)
		0.5 <b>Μ</b> Ω~20GΩ	0%~20
_	1000V	<b>2M</b> Ω~10GΩ	±(3%+5)
		1 <b>Μ</b> Ω~40GΩ	
	1500V	5 <b>Μ</b> Ω~20GΩ	±(3%+5)
	05001	<b>2.5M</b> Ω~100GΩ	$0\%\sim20$ $\pm(3\%+5)$ $\pm(3\%+5)$ $\pm(3\%+5)$ $\pm(3\%+5)$ $\pm(2\%+5)$ $\pm(2\%+5)$
	2500V	10 <b>Μ</b> Ω~100GΩ	
	1000V		
DC Voltage (V)	600V		$ \begin{array}{c} \pm(3\%+5) \\ \pm(3\%+5) \\ \\ \pm(3\%+5) \\ \\ \pm(3\%+5) \\ \\ \pm(2\%+5) \\ \\ \pm(2\%+5) \\ \end{array} $
AO 1/-14 AD	750V		
AC Voltage (V)	600V		±(2%+5)
Short-circuit current			<1.8mA
Low Resistance (Ω)	0.1Ω~999.9Ω		

## GAZELLE

Features				
Auto range/Auto Power Off		$\checkmark$		
Test voltage secondary display				
Low Battery Indication		$\checkmark$		
Data Storage		18		
Comparison Measurement		$\checkmark$		
Polarization Index (PI)		$\checkmark$		
Dielectric absorption ratio (DAR)		$\checkmark$		
USB Interface		$\checkmark$		
Analog bar graph		30		
LCD Backlight		$\checkmark$		
Over-range Warning		$\checkmark$		
High Voltage Indication		$\checkmark$		
Timing Measurement	Around 30 minutes			
	Around 15 minutes			